



LICHENS ENVIRONMENT PVT LTD.

ENVIRONMENT CONSULTANT & MANUFACTURERS OF RO, DM, PORTABLE STP, ETP, CETP, LANDSCAPING, RAIN WATER HARVESTING

School no. 3

Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	-----	Odourless	Agreeable
2	pH value	-----	8.32	6.5-8.5
3	Total Dissolve Solids	Mg/L	160	Max 1500
4	Turbidity	NTU	2.15	Max 10
5	E-coli	(cfu)	0	0

School no. 4

Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	-----	Odourless	Agreeable
2	pH value	-----	8.15	6.5-8.5
3	Total Dissolve Solids	Mg/L	290	Max 1500
4	Turbidity	NTU	1.01	Max 10
5	E-coli	(cfu)	0	0

School no. 5

Sr.no.	Name of Test	Unit	Result	Limit (Min-Max)
1	Odour	-----	Odourless	Agreeable
2	pH value	-----	8.21	6.5-8.5
3	Total Dissolve Solids	Mg/L	280	Max 1500
4	Turbidity	NTU	1.37	Max 10
5	E-coli	(cfu)	0	0

Vinod Bansal

ईनु बंसल / INU BANSAL

प्रधानाचार्या / Principal

परमाणु ऊर्जा केन्द्रीय विद्यालय क्र-५


ATOMIC ENERGY CENTRAL SCHOOL NO-5

अणुशक्तिनगर, मुंबई - ९४ / Anushakti Nagar, Mumbai-94,

Regd. Office / Sangeet CHSL.-12, D-13, Jesa Park,
Bhayander (E), Mumbai - 401 105.

Cell : +919821844466, +919322291420

Email : admin@lichens.in



प्री. आर. मोरे / P.R. MORE
Branch Office : 1st Flr., Dairy Farm, 91, Masoodpur,
Vasant Kunj, New Delhi - 110 070.
Cell : +919870333525
Email : lichensindia@hotmail.com
accounts@lichens.in

मुंबई - ४०००९४ / Mumbai - 400094

www.lichens.in

NBR

27/05/2023